

## **NOTES:**

- HYDRANT MARKER POST IS TO BE LOCATED SUCH AS TO MINIMIZE INTERFERENCE WITH PEDESTRIAN TRAFFIC AND TO LEAVE MINIMUM 6 FEET CLEAR ZONE FOR SIDEWALK SNOW PLOW OPERATIONS.
- 2. PREFERRED LOCATION OF HYDRANT MARKER POST IS DIRECTLY BEHIND HYDRANT. IF HYDRANT MARKER POST CANNOT BE SET AT THAT LOCATION IT MAY BE SET AT ONE OF OTHER LOCATIONS AS SHOWN. REGARDLESS OF LOCATION HYDRANT MARKER POST IS NOT TO BLOCK ACCESS TO ANY HYDRANT NOZZLE.
- HYDRANT MARKER POST IS TO BE SET VERTICALLY PLUMB AND WITH EDGE FLANGES FACING AWAY FROM HYDRANT.
- 4. IN AREAS OF FULL WIDTH SIDEWALK HYDRANT MARKER POST LOCATION WILL BE AS APPROVED BY CITY.
- 5. HYDRANT MARKER POST IS NOT TO BE INSTALLED WITHIN GENERAL LIMITS OF CENTRAL BUSINESS DISTRICT.

## CITY OF ROCHESTER

## HYDRANT MARKER POST

ISSUED	9-2-91	STD.	DWG.
REVISED	6-1-09	NO.	R917-3