



NOTES:

1. LOCATION OF SAMPLING TAPS ARE SUBJECT TO PRIOR APPROVAL BY CITY AND MONROE COUNTY DEPARTMENT OF PUBLIC HEALTH.
2. IF SAMPLING TAP IS LOCATED IN PAVED AREA, SAMPLING TAP IS TO BE KEPT BELOW GROUND EXCEPT WHEN IN USE.
3. IF APPROVED BY CITY, SAMPLING TAP MAY BE LOCATED AT SAME LOCATION AS NEW WATER SERVICE.
4. IF SAMPLING TAP IS NOT TO BE USED AS NEW WATER SERVICE, UPON NOTIFICATION OF ACCEPTABLE SAMPLE RESULTS, CORPORATION STOP IS TO BE REMOVED AND REPLACED WITH A BRASS PLUG OR CORPORATION STOP IS TO BE CLOSED, WATER SERVICE PIPE DISCONNECTED FROM CORPORATION AND BRASS CAP INSTALLED ON OUTLET OF CORPORATION STOP.
5. MAXIMUM DISTANCE BETWEEN SAMPLING TAPS ON NEW WATER MAIN INSTALLATION IS 1,000 FEET.

CITY OF ROCHESTER		
DISINFECTION SAMPLING TAP		
ISSUED	1-13-06	NON-STANDARD DWG.NO.S900-6
REVISED	2-19-15	