



LEGEND:

- ① 3/4 INCH TAPPING SADDLE w/FPT OUTLET THREADS AND 3/4 INCH CURB STOP w/MPT ENDS. PADLOCK WINGS AND THREADED CAP ON OUTLET
- ② SEPARATE STRAINER REQUIRED FOR COMPOUND AND TURBO METERS ONLY
- ③ RISING STEM FLANGED GATE VALVE w/HAND WHEEL (OPEN LEFT)
- ④ NON-RISING STEM MECHANICAL JOINT GATE VALVE (OPEN RIGHT) w/MECHANICAL JOINT RESTRAINT
- ⑤ MECHANICAL JOINT FITTING w/MECHANICAL JOINT RESTRAINT

NOTE:

FOR WATER METER AND WATER METER VAULT DIMENSIONS, CLEARANCES AND NOTES, SEE DETAIL S920-3

CITY OF ROCHESTER		
WATER METER VAULT		
FOR		
DOMESTIC METER		
3 INCH TO 10 INCH		
ISSUED	9-4-01	NON-STANDARD DWG.NO.S920-2
REVISED	9-16-13	