



### ELEVATION

**NOTES:**

1. METER AND METER COUPLINGS ARE TO BE FURNISHED BY THE WATER BUREAU AND INSTALLED BY THE PLUMBER. METER AND COUPLINGS ARE AVAILABLE FOR PICK-UP AT THE WATER BUREAU OPERATIONS CENTER, 10 FELIX STREET, TELEPHONE 428-7618.
2. METERS MUST BE MOUNTED HORIZONTALLY AND SET IN A HEATED LOCATION THAT IS READILY ACCESSIBLE FOR REPAIR, READING AND REPLACEMENT. METERS CAN NOT BE LOCATED IN CRAWL SPACES, CEILINGS OR IN CONFINED SPACES.
3. THE WATER BUREAU WILL INSPECT AND SEAL THE METER AND WILL ALSO INSTALL REMOTE TOUCH PAD OR RADIO READING DEVICE.
4. A BACKFLOW PREVENTION DEVICE MAY BE REQUIRED ON SOME WATER SERVICES 1" AND SMALLER, AS DETERMINED BY THE WATER BUREAU.
5. PIPE AND APPURTENANCES ARE TO BE ADEQUATELY RESTRAINED, BRACED AND SUPPORTED. ALL WORK AND MATERIALS SHALL BE IN CONFORMANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL PLUMBING CODES.

DIMENSIONS			
METER SIZE	METER LENGTH "A"	APPROX. CLEAR OPENING "B"	MIN. CLEAR METER TO WALL
5/8"	7 1/2"	13" +/-	6"
5/8" x 3/4"	7 1/2"	13" +/-	6"
3/4"	9"	15" +/-	6"
1"	10 3/4"	17" +/-	8"

<b>CITY OF ROCHESTER</b>		
<b>INDOOR INSTALLATION OF WATER METER 1 INCH AND SMALLER</b>		
ISSUED	7-13-11	<b>NON-STANDARD DWG.NO.S970-2</b>
REVISED	9-16-13	