



**AT STRUCTURE
 OR APPURTENANCE**

**AT
 LAWN AREA**

NOTES:

1. MAXIMUM CROSS-SLOPE OF SIDEWALK IS 1:50.
2. SIDEWALK ACCESS RAMP AND LANDING PAD IS TO BE 7 INCH THICK CLASS K CONCRETE.
3. PROVIDE 1/2 INCH WIDE EXPANSION JOINT BETWEEN NEW CONCRETE CONSTRUCTION AND BACK EDGE CURB, CONCRETE GUTTER, OTHER PAVED AREAS, BUILDINGS, WALLS, POLE BASES AND OTHER STRUCTURES/ APPURTENANCES.
4. EXPANSION JOINT: 1/2 INCH WIDE PREMOULDED EXPANSION JOINT MATERIAL, SEAL WITH CAULKING SEALANT 1/2 INCH WIDE 5/8 INCH DEEP.

CITY OF ROCHESTER		
CONCRETE SIDEWALK AND DRIVEWAY		
ISSUED	9-2-91	STANDARD DWG.NO.R608-6
REVISED	12-1-15	