



NOTES :

1. ADJUST RADII TO FIT SITE CONDITIONS.
2. CROSS SLOPE OF SIDEWALK TO BE 1.50%.
3. ENTIRE SIDEWALK AREA WITHIN LIMITS OF RADIUS TO BE 7 INCHES THICK CLASS K CONCRETE.

CITY OF ROCHESTER		
TYPICAL LAYOUT OF SIDEWALK AT INTERSECTION		
ISSUED	5-1-10	NON-STANDARD DWG.NO.S608-31
REVISED	7-1-17	