



**NOTES:**

1. APPROPRIATE MEASURES ARE TO BE TAKEN TO PREVENT SURFACE WATER, GROUND WATER, MUD AND FOREIGN MATERIAL FROM ENTERING SEWER SYSTEM DURING CONSTRUCTION.
2. REMOVE PORTION OF EXISTING SEWER MANHOLE RISER AS NECESSARY TO RETROFIT FRAME AND COVER TO REQUIRED FINISHED ELEVATION AND ON SOUND BEARING. FOR ADJUSTMENT USE NEW CONCRETE ADJUSTMENT RING SET ON 1/2 INCH MORTAR BED, OR BRICK/BLOCK AND MORTAR.
3. ALL COURSES ARE TO BE COATED WITH 1 COAT OF TAMMS DURALKOTE 500, OR APPROVED EQUIVALENT.
4. LOWER LIMIT OF CLASS K CONCRETE ENCASEMENT IS TO BE BELOW LOWEST PORTION OF LEVELING COURSE.
5. ALL NEW BRICK IS TO BE 8000 PSI RED SEWER BRICK.

<b>CITY OF ROCHESTER</b>		
<b>SEWER MANHOLE FRAME AND COVER LOWERING GRADE</b>		
<b>ISSUED</b>	10-18-02	<b>NON-STANDARD DWG.NO.S604-11</b>
<b>REVISED</b>	7-31-12	