





## NOTES:

- 1. MINIMUM WIDTH OF ACCESS RAMP IS 4 FEET.
- 2. SURFACE OF ACCESS RAMP TO BE FIRM, STABLE AND SLIP-RESISTANT. TEXTURE SURFACE WITH COARSE BROOM RUNNING TRANSVERSE TO SLOPE OF ACCESS RAMP.
- 3. ENTIRE AREA OF ACCESS RAMP AND SIDE FLARES TO BE 7 INCH THICK CONCRETE.

## CITY OF ROCHESTER

## SIDEWALK ACCESS RAMP TYPE A

ISSUED	9 - 2 - 91	STANDARD
REVISED	7 - 1 - 17	DWG.NO.R608-I