



HOT DIPPED GALVANIZED

NOTES:

1. PULLBOX IS TO BE MADE OF CAST-IN-PLACE OR PRECAST CLASS K CONCRETE.
2. FRAME AND COVER ARE TO BE GRAY CAST IRON PER ASTM A48 CLASS 30 IN CONFORMANCE WITH THE REQUIREMENTS OF NYSDOT SECTION 715-05.
3. SIZE OF LETTERS TO BE 2 INCH.
4. TOP OF PULLBOX TO BE SET FLUSH IN PAVED AREA AND 1 INCH ABOVE GRADE IN LAWN AREA.

CONDUIT MAY ENTER
PULLBOX AT ANY ANGLE
OR LOCATION - MINIMUM
3" FROM BOTTOM



CITY OF ROCHESTER	
CONCRETE PULLBOX (24 INCH)	
ISSUED	9-2-91
REVISED	4-28-06
STD. DWG. NO. R671-2	