



NOTES:

1. SURVEY MONUMENT TO BE SET PLUMB.
2. TOP OF SURVEY MONUMENT TO BE MINIMUM 4 INCHES AND MAXIMUM 6 INCHES BELOW FINISHED GRADE.
3. BACKFILL EXCAVATION WITH SELECT GRANULAR FILL COMPACTED IN 6 INCH LAYERS.
4. MONUMENT IS TO BE MARKED WITH 3/8 INCH DEEP, 1/8-1/4 INCH DIAMETER DRILL HOLE AFTER INSTALLATION PER SPECIFICATION SECTION S626-3.04.
5. FOR SURVEY MONUMENT FRAME AND COVER SEE DETAIL S626-7.

CITY OF ROCHESTER		
SURVEY MONUMENT		
ISSUED	9-2-91	STANDARD
REVISED	12-17-20	DWG.NO.R626-1