



NOTES :

1. TEMPORARY PAVEMENT MATERIAL IS TO BE MINIMUM 2 INCHES THICK TYPE 19 F9 BINDER COURSE HMA/WMA 80 SERIES COMPACTION, RECYCLED ASPHALT, OR ASPHALT MILLINGS. ASPHALT COLD PATCH MATERIAL IS UNACCEPTABLE FOR USE AS TEMPORARY PAVEMENT.
2. DURING WINTER SEASON (NOVEMBER 1 THRU APRIL 14), IF HMA/WMA MATERIAL IS NOT AVAILABLE, USE CLASS F OR HES CONCRETE FOR TEMPORARY PAVEMENT. CONCRETE IS TO BE MINIMUM OF 4 INCHES THICK FOR ARTERIAL AND COLLECTOR STREETS, 3 INCHES THICK FOR RESIDENTIAL STREETS AND ALLEYS, WITH SURFACE BROOM FINISHED.
3. TEMPORARY PAVEMENT IS TO BE PLACED AS SOON AS BACKFILLING OPERATIONS HAVE BEEN COMPLETED, AND AS REQUIRED BY RESIDENT PROJECT REPRESENTATIVE AND WITHIN 24 HOURS AFTER HAVING RECEIVED NOTICE.
4. TEMPORARY PAVEMENT MATERIAL IS TO BE COMPACTED TO PROVIDE SURFACE THAT IS FIRM AND SMOOTH, SLIP RESISTANT, WELL DRAINED, AND FULLY ACCESSIBLE FOR PERSONS WITH DISABILITIES.

CITY OF ROCHESTER		
TEMPORARY PAVEMENT		
ISSUED	9-2-91	STANDARD
REVISED	11-30-21	DWG.NO.R412-1