



NOTES :

1. CASTING AND TOP OF CONCRETE ARE TO BE IN SAME HORIZONTAL PLANE AS SURROUNDING SURFACE, TRUE TO LINE AND GRADE, WITH GRATE HAVING FULL CONTINUOUS AND UNIFORM BEARING CONTACT WITH FRAME.
2. TOP OF GRATE TO BE LEVEL WITH TOP OF FRAME, STABLE AND IMMOVABLE WHEN IN PLACE AND WHEN UNDER INFLUENCE OF TRAFFIC OR ANY OTHER TYPE OF LOAD BEARING STRESS FRAME IS TO BE SET PARALLEL AND FLUSH WITH CURB.
3. DEPTH OF CONCRETE TO BE MINIMUM 12 INCHES. ACTUAL DEPTH TO BE TO CONSTRUCTION JOINT OR SOUND BRICK/ CONCRETE.
4. HIGH EARLY STRENGTH CONCRETE TO BE USED FOR PLACEMENTS REQUIRED TO SATISFY OPEN TO TRAFFIC TIME REQUIREMENTS.
5. DURING AND AFTER DEPOSITION OF CONCRETE PERFORM MODERATE VIBRATION AND COMPACTION TO EXPEL LARGE BUBBLES AND EXCESS OF ENTRAPPED AIR FROM FRESHLY PLACED CONCRETE IN ACCORDANCE WITH NYSDOT SECTION 555-3.04 HANDLING AND PLACING CONCRETE.
6. WIDTH OF CONCRETE COLLAR TO BE SAME ON ALL SIDES.
7. REMOVE/ADD COURSES BRICK, MORTAR OR CONCRETE TO ADJUST TOP OF WALLS TO SET FRAME AND GRATE TO FINISHED GRADE AND ON SOUND BEARING. PRIOR TO POURING CONCRETE COAT TOP SURFACE OF WALL WITH NYSDOT 721-03 EPOXY POLYSULFIDE GROUT.
8. COAT INTERIOR SURFACE OF NEW CONCRETE WITH 2 COATS OF DURALKOTE 500 EPOXY OR APPROVED EQUIVALENT, AND EXPOSED EXTERIOR SURFACE OF NEW CONCRETE WITH 2 COATS OF BITUMINOUS COATING.

CITY OF ROCHESTER		
CONCRETE COLLAR FOR EXISTING CAPSTONE CATCH BASIN		
ISSUED	6-24-19	NON-STANDARD
REVISED	12-30-21	DWG.NO.S604-96